FirstPower[®] Shenzhen All Technology Co., Ltd Tel: +86-755-89896797 Fax: +86-755-28851555

Specification confirmation

Product name	Ternary lithium battery pack
Product model	LFP-GP72200
Customer code	
Document number	
Version number	A/0
Issue date	2021-12-20

Approved by	Approved by Reviewed by Prepared by	
Song Guo Song	Hai Yang	Kui Yuan

	Autograph	Date
Customer confirmation	Company Name:	
	Company Seal:	

Content

1. Scope
2. Product Pict
3. Basic parameters of battery2
4. BMS Configuration
5. BMS Protection Parameters
5. Cell technical parameters5
7.2D diagram of the cell
8. Electrical performance
D. Use warning
10. Battery operation instruction
11. Other The Chemical Reaction9
Note:

1. Scope

This specification describes the basic performance, technical requirement, testing method, warning and caution of Li- ion rechargeable battery .The specification only applies to Shenzhen All Technology Co., Ltd

2. Product Pict



3. Basic parameters of battery

Battery Model	72200
Size (L*W*H)mm	850*260*380
Weight (kg)	≤112kg

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241 Huachang Road, LongHua District, Shenzhen,China Tel: +86-755-89896797 Post Code:518109

Battery Rated Capacity (0.2C)	200Ah		
Battery Rated Voltage	74V		
Operating Voltage Range	55-84V		
Battery Type	Ternary lithium		
Standard charging current	30A		
Continuous Charging Current (Max.)	200A		
Continuous Discharge Current (Max.)	200A		
Peak Discharge Current	400A(3S)		
Internal Resistance (mΩ)	50 mΩ		
Storage Temperature	10°C~35°C		
Storage Humidity	10%~90% RH		
Shipping Voltage	51V~52V		
Charging Temperature	0~55°C		
Discharge Temperature	-20~55°C		
Cooling Mode	Natural Cooling		
Waterproof Level	IP56		
Communication method	Bluetooth		
Display	LCD		
Battery Cycle Life	3000 times (standard charge and discharge)		
	Temperature : 23±5°C		
Standard Environmental Condition	Humidity : 45-75%RH		
	Atmospheric Pressure : 86-106 KPA		

4. BMS Configuration

Function	Configuration	Function	Configuration
Number of batteries in series and parallel	22S2P	Battery packs in parallel	NO
Continuous current	200A	Battery packs in series	NO
Number of NTCs	1 built-in, 2 external	Module of Bluetooth	Optional
Balance Function	Passive balance	LCD display	Optional

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241Huachang Road, LongHua District, Shenzhen, China
Post Code: 518109

Interface Type	Optional	Heating function	Optional

5. BMS Protection Parameters

F	During	<u>s</u>	Specification		TT A (
Function	Project	MIN	ТҮР	MAX	Unit
Overvoltage protection voltage		4.22	4.25	4.28	V
Cell Overvoltage Protection	Overcharge protection delay time	1000	2000	3000	mS
	Overcharge protection restores voltage	4.10	4.15	4.20	V
	Over-discharge protection voltage	2.70	2.80	2.90	V
Cell Over-discharge	Over-discharge protection delay time	1000	2000	3000	mS
protection	Over-discharge protection recovery voltage	2.90	3.00	3.10	V
	Over-discharge protects recovery conditions	The voltage recovers or the charge resume		ge resumes	
	Charge overcurrent protection value	205	210	215	A
Charging overcurrent protection	Charging overcurrent delay	7	10	13	S
	Charging overcurrent discharge conditions	Automatic recover after a delay of 32S			y of 32S
	1st Overcurrent Discharge	205	210	215	А
	1st Overcurrent Discharge delay	7	10	13	S
Overcurrent Discharge	2nd Overcurrent Discharge	420 460 500		А	
	2nd Overcurrent Discharge delay	150	320	320 500	
	Overcurrent Discharge Release	Automatic recovery after a delay		ay of 32S	
	Short circuit protection current	720	900	1080	А
Short Circuit Discharge	Short circuit protection delay time	200	200 400 800		uS
	Short circuit protection recovery	Recove	er after 5S del	ay after disco load	nnecting the

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241 Huachang Road, LongHua District, Shenzhen, China
Tel: +86-755-89896797Post Code:518109


	Short circuit description: short circuit current less than the minimum or higher than				
	the maximum value may cause short circuit protection failure, short circuit current				
	more than 2000A, there is no guarantee of short circuit protection, and it is not				
	recomme	ended to do sho	ort circuit prote	ction test.	
Discharge high temperature protection	Temperature protection value	70	75	80	°C
(external)	Temperature protection release value	60	65	70	°C
Discharge Low Temperature protection	Temperature protection value	-25	-20	-15	°C
(external)	Temperature protection release value	-15	-10	-5	°C
High temperature charging protection	Temperature protection value	60	65	70	°C
(external)	Temperature protection release value	50	55	60	°C
Low temperature charging protection	Temperature protection value	-15	-10	-5	°C
(external)	Temperature protection release value	-10	-5	0	°C
FET discharge high temperature protection	Temperature protection value	85	90	95	°C
(built-in curing)	Temperature protection release value	50	65	80	°C
	Balanced opening voltage	3.97	4.00	4.03	V
	Opening voltage difference		15		mV
Balanced function	Balanced current	10		70	mA
	Balanced mode	Charge Balance /Static Balance			
	Balanced type	Time-sharing Balance/Pulse Balance			nce

6. Cell technical parameters

No.	Item		Parameter	Remark
	Nominal Capacity		100.0Ah	
1	Турі	cal Voltage	3.7V	(25±2)°C, Standard charge and discharge
	AC Impedance Resistance(1KHz)		≤1.0mΩ	uisenarge
	Width		161.0 ±1.0mm	
2	Dimension Thickness		10.0 ±0.25mm	
		High (total)	247.75 ±1.0mm	Refer to 6
3	Battery weight		833g±15g	

7. 2D diagram of the cell

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241Huachang Road, LongHua District, Shenzhen, China
Post Code:518109



8. Electrical performance

No.	Item	Requirements	Measuring Procedure
1	Rate Discharge Performance at 25℃	Discharge capacity/nominal capacity×100% A) 0.5CA ≥100% B) 1.0CA ≥98%	After standard charge and 1h rest, discharge to 55V cutoff with the current of 0.5C(A), 1.0C(A), respectively. If the discharge capacity fails to meet the technical requirements, this test is allowed to be repeated three times

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241Huachang Road, LongHua District, Shenzhen, China
Post Code: 518109

2	Discharge Performance at different temperature	Discharge capacity/nominal capacity×100% A)55℃ 1.0C≥95% B)-20℃ 1.0C≥70%	Measure the initial capacity and state of the battery: A) after standard charge and 5h restate 55° C, discharge to 55V cutoff with the current of 1.0C(A); B) after standard charge at $25\pm2^{\circ}$ C and 4h rest at -20° C $\pm2^{\circ}$ C, discharge to 45V cutoff with the current of 1.0C(A).
3	Capacity Retention and Capacity Recovery at 25°C	Capacity Retention≥95% Capacity Recovery≥97%	Measure the initial capacity and state of the battery, after standard charge and stored for 28 days, discharge to 55V cutoff with the current of 0.5C(A), calculate the remaining capacity, the retention can be expressed as a percentage of nominal capacity. After standard charged and 30mins rest, calculate the discharging capacity (Ah), the recovery can be expressed as a percentage of nominal capacity. The recovery is measured with discharge current 0.5CA with 55V cut-off at $(25\pm2)^{\circ}C$.
4	Cycle Life at 25℃	≥3000cycle @1.0C/1.0C	Under the 200kgf clamp, after standard charged and 30mins rest, discharge to 55V cutoff with the current of 1.0C (A) at (25 ± 2) °C, and then start the next cycle, end with the capacity decreasing to 80% of the initial capacity. The number of cycles is defined as the cycle life of the battery.
5	Cycle Life at 35℃	≥2400 cycle @1.0C/1.0C	Under the 200kgf clamp, after standard charged and 30mins rest, discharge to 55V cutoff with the current of 1.0 C (A) at (35 ± 2) °C, and then start the next cycle, end with the capacity decreasing to 80% of the initial capacity. The number of cycles is defined as the cycle life of the battery.
6	Cycle Life at 45℃	≥1600 cycle @1.0C/1.0C	Under the 200kgf clamp, after standard charged and 30mins rest, discharge to 55V cutoff with the current of 1.0 C (A) at (45 ± 2) °C, and then start the next cycle, end with the capacity decreasing to 80% of the initial capacity. The number of cycles is defined as the cycle life of the battery.
7	End of life management	capacity/nominal capacity <70%	During the use of the battery, the battery shall be stopped when the end of life regulations is exceeded.

9. Use warning

In order to use and handle the battery safely, please read the operating instructions carefully before use

- Do not expose the battery to the sun or throw it in a fire.
- When charging the battery, the positive and negative polarities cannot be reversed.
- Do not short-circuit the positive and negative poles of the battery pack with wires or other metal objects!

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241 Huachang Road, LongHua District, Shenzhen,China Tel: +86-755-89896797 Post Code:518109

- Do not pierce the battery pack housing with nails or other sharp objects, and do not hammer or pedal the battery pack!
- Do not disassemble or deform the battery.
- Do not immerse the battery in water.
- Never place the battery pack in a microwave oven or pressure vessel!
- Do not use the battery pack in an extremely hot environment, such as in direct sunlight or in a car on a hot day. Otherwise, the battery pack will overheat, which will affect performance and shorten the life of the battery pack.
- Do not mix batteries of different manufacturers, types and models.
- Do not allow children to touch the battery.
- If the battery pack emits odor, heat, deformation, discoloration or any other abnormal phenomenon, do not use it. If the battery pack is in use or charging, immediately remove it from the car (electrical appliance) or charger and stop using it!
- If the electrolyte gets into the eyes after the battery leaks, do not wipe it, flush it with water immediately, and seek medical assistance immediately. If it is not handled in time, the eyes will be injured!

Charge and discharge

- The battery must be charged under suitable conditions.
- Never charge the battery with a faulty charger.
- The battery can't be charged continuously for more than 24H.
- Do not charge the battery pack in the presence of fire or extreme heat! Do not use or store battery packs near heat sources such as fire or heaters! If the battery leaks or emits peculiar smell, immediately move it away from the open flame. When using the battery for the first time, fully charge the battery before using it.
- During the charging and discharging process of the battery pack, if there is an odor or abnormal sound, please stop charging and discharging immediately.
- The ambient temperature will affect the discharge capacity. When the ambient temperature exceeds the standard environment (25±5°C), the discharge capacity will be reduced!

Storage

• The battery is stored in a ventilated and dry environment.

Disposal

• The laws and regulations of different countries are different, and the disposal should be based on the local laws and regulations.

10. Battery operation instruction

10.1 Charging

Charging current: The maximum charging current specified in the specification cannot be exceeded.

Charging voltage: cannot exceed the highest limit voltage specified in the specification.

Charging temperature: The charging temperature of the battery must be performed in accordance with

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241 Huachang Road, LongHua District, Shenzhen, China Tel: +86-755-89896797 Post Code:518109 the temperature ranges of the specification. Charge in constant current and then in constant voltage mode, and reverse charging is prohibited. It is dangerous to charge the battery with the polarity reversed.

10.2 Discharging current

The discharge current of the battery cannot exceed the maximum discharge current specified in the specification. Excessive current discharge will cause the battery to heat up and reduce its capacity.

10.3 Discharge temperature

The battery discharge temperature must be performed within the temperature range of the specification.

10.4 Over-discharges

Short-term overcharge and over-discharge will not affect the use of the battery, but long-term over-discharge will affect the function of the battery, and the battery will be permanently unsuitable. Another reason why the battery may be over-discharged is the disappearance of automatic energy. The way to prevent battery over-discharge is that the battery should maintain a certain amount of power.

10.5Storage battery

The battery is stored within the temperature range specified in the specification. If the battery is stored for more than six months, it is recommended that you start charging the battery.

11. Other The Chemical Reaction

Since the battery uses the principle of chemical reaction, the performance of the battery will decrease with time, even if it is stored for a long time without use. If the conditions of use such as charging, discharging and ambient temperature are not within the specified range of use, the service life of the battery will also be shortened, or liquid leakage will result in equipment damage. If the battery cannot be charged for a long period of time, even if the charging method is correct, the battery needs to be replaced.

Note:

Matters not included in this manual shall be determined by mutual agreement.

Add: 4th Floor, Building 49, Jiahe Zhihui Innovation Park, No. 241 Huachang Road, LongHua District, Shenzhen, China Tel: +86-755-89896797 Post Code:518109